
IIIIHUNT Dimming

# **Omega Series** Controls HUNT Simplicity<sup>®</sup> Architectural Full Range Fluorescent Dimmers for use with Electromagnetic Fluorescent Lighting 120V and 277V





SCF-1527

Product Description:

120V

SCF-5

**SCF-10** 

- Commercial-grade wall controls for T12 fluorescent lamps (compatible ballast requiredsee below).
- lvory and white standard colors; custom colors available.
- No exposed heat sink.
- Limited one-year warranty. •

# Features:

Easy-to-operate, smooth-sliding linear control.

277V

SCF-1027

- Solid-state circuitry.
- RFI filter.
- UL Listed. •
- Fits in a standard 2" deep single-gang back box.
- Maximum number of lamps controlled by one dimmer: • SCF-5, SCF-527: 12 lamps SCF-10: 18 lamps SCF-1027: 20 lamps SCF-15: 28 lamps SCF-1527: 30 lamps

| Compatible Ballasts                                      |                                |  |  |
|--|--------------------------------|--|--|
| 120V   |                                |  |  |
| GE-Valmont 8G-1718 Advance Dim 240-H-TP (2 lamp)         |                                |  |  |
| GE-Valmont 8G-5001 Universal 550-L                       |                                |  |  |
| GE-Valmont 8G-5007 (2 lamp) Universal 550-L-TC-P         |                                |  |  |
| Advance Dim 140-H  | Universal 502-A (2 lamp)       |  |  |
| Advance Dim 140-H-TP                                     | Universal 502-A-TCF-P (2 lamp) |  |  |
| Advance Dim 240-H (2 lamp) Advance Dim 240-H-TP (2 lamp) |                                |  |  |
| 277V   |                                |  |  |
| Universal 679-L-TC-P                                     |                                |  |  |
| Universal 678-A (2 lamp)                                 |                                |  |  |

# Dimming.

It's all we do.

Dimensions: SCF-5, SCF-10, SCF-527, SCF-1027 faceplate dimensions: 3"W x 4 1/2"H SCF-15, SCF-1527 faceplate dimensions: 4 3/4"W x 4 1/2"H Backbox dimensions on all models: 1 5/8" x 2 5/8" x 1 3/8"

Since 1960.

50

# SCF-527

Tel: (970) 484-9048

Hunt Control Systems Inc.

Fort Collins CO 80524

200 Rome Court

Fax: (970) 493-4125

huntdimming.com



# Installation and Wiring Instructions for HUNT *Simplicity®* Architectural Electromagnetic Fluorescent Controls Single Pole and Three Way 120V, 60Hz

These dimmers are designed for electro-magnetic fluorescent, permanently installed fixtures using an approved ballast (see below) and rapid start 40 watt lamps.

#### Models:

A-Line Series: AF-5, AF-5-3W, AF-10, AF-15 Accent Series: ASF-5, ASF-5-3W, ASF-10, ASF-15 Omega Series: SCF-5, SCF-10, SCF-15

| Load: (A minimum load of two (2) lamps is required) |          |
|---|----------|
| AF-5, AF-5-3W, ASF-5, ASF-5-3W, SCF-5;              | 12 lamps |
| AF-10, ASF-10, SCF-10;                              | 18 lamps |
| AF-15, ASF-15, SCF-15;                              | 28 lamps |

### **Caution:**

To reduce the risk of overheating and possible damage to other equipment, do not install to control a receptacle, a motor-operated appliance, or a transformer-supplied appliance.

### Avertissement:

Pour réduire le risque de surchauffes et les dommages possibles à l'autre équipement, ne pas installer pour contrôler une prise, un appareil moteur-fonctionné, ou un transformateur d'alimentation magnétique appareil fourni.

#### **Read Carefully Before Installing Dimmers:**

To avoid fire, personal injury, and/or damage to dimmer, turn power *OFF* at circuit breaker and test that power is *OFF* before wiring.

#### Notes:

- Fins must be mounted in vertical position and must not be recessed into the wall. When stacking dimmers or mounting one above the other, allow a minimum of three inches of clear wall space between the upper and lower finned plates.
- 2.) The aluminum chassis of this lighting control is designed as a heat sink to dissipate heat generated by the proper functioning of the circuit components. The fins may be very warm to the touch when the lighting control is operating at its maximum rated load. This is normal operation and does not indicate malfunction.
- 3.) Due to electro-magnetic radiation produced by all solid state lighting controls, the load, dimmer, and connecting wires should be located as far away as possible from radios, intercom units or public address systems. Six feet is the recommended minimum distance.
- 4.) Burn-in lamps at fullbright for a minimum 100 hours before attempting to dim and adjust trim.

5.) Dimmers may be ganged in any combination. See reverse for derating and wallbox size.

#### Wiring Diagrams: See reverse side.

| Compatible Ballasts         |                               |  |
|-----------------------------|-------------------------------|--|
|                             | 120V                          |  |
| GE-Valmont 8G-5001          | Advance Dim 240-H-TP (2 lamp) |  |
| GE-Valmont 8G-5007 (2 lamp) | Universal 550-L               |  |
| Advance Dim 140-H           | Universal 550-L-TC-P          |  |
| Advance Dim 140-H-TP        | Universal 502-A (2 lamp)      |  |
| Advance Dim 240-H (2 lamp)  | Universal 502-A-TC-P (2 lamp) |  |

(Additional ballasts may also be compatible with this dimmer. Call HUNT to verify compatibility.)


# Hunt Control Systems, Inc.

200 Rome Court Fort Collins, CO 80524 Ph: (970) 484-9048 www.huntdimming.com




# Wiring Diagrams and Ganging Information for HUNT Simplicity® **Architecural Electromagnetic Fluorescent Controls** Single Pole and Three Way 120V, 60Hz

# Standard Installation Single Pole Wiring Diagram




# Three Way Wiring Diagram



#### GANGING:

When ganging two dimmers, break off the inside fins; when ganging three or more, break off the inside fins of the outer units, and both sides of the inner unit(s). Break off as shown.

Derating of 10% per side is necessary when fins are removed.



#### Wallbox Requirements For Ganging

|   | Number of double gang units |   |   |   |    |    |
|---|-----------------------------|---|---|---|----|----|
|   |                             | 0 | 1 | 2 | 3  | 4  |
| Number<br>of<br>single<br>gang<br>units   | 0                           | _ | 1 | 3 | 5  | 7  |
|   | 1                           | 1 | 3 | 5 | 7  | 9  |
|   | 2                           | 2 | 4 | 6 | 8  | 10 |
|   | 3                           | 3 | 5 | 7 | 9  | 11 |
|   | 4                           | 4 | 6 | 8 | 10 | 12 |
| Minimum size wall box required (in gangs) |                             |   |   |   |    |    |

#### Hunt Control Systems, Inc. 200 Rome Court Fort Collins, CO 80524 Ph: (970) 484-9048 www.huntdimming.com

#### LOW END BRIGHTNESS ADJUSTMENT THE LOW END BRIGHTNESS IS FACTORY ADJUSTED. IF NOT SATISFACTORY, IT MAY BE TRIMMED AS FOLLOWS: Rotate dimmer control knob to full counter-

clockwise (with unit turned on). Adjust trim to desired brightness with a small screwdriver.

40 WATT LAMP





# Installation and Wiring Instructions for HUNT *Simplicity®* Architectural Electromagnetic Fluorescent Controls Single Pole and Three Way 277V, 60Hz

These dimmers are designed for electro-magnetic fluorescent, permanently installed fixtures using an approved ballast (see below) and rapid start 40 watt lamps.

#### Models:

A-Line Series: AF-527, AF-527-3W, AF-1027, AF-1027-3W, AF-1527 Accent Series: ASF-527, ASF-527-3W, ASF-1027, ASF-1027-3W, ASF-1527 Omega Series: SCF-527, SCF-1027, SCF-1527

Load: (A minimum load of two (2) lamps is required)

| AF-527, AF-527-3W, ASF-527, ASF-527-3W, SCF-527:      | 12 lamps |
|---|----------|
| AF-1027, AF-1027-3W, ASF-1027, ASF-1027-3W, SCF-1027: | 20 lamps |
| AF-1527, ASF-1527, SCF-1527:                          | 30 lamps |

# Caution:

To reduce the risk of overheating and possible damage to other equipment, do not install to control a receptacle, a motor-operated appliance, or a transformer-supplied appliance.

#### Avertissement:

Pour réduire le risque de surchauffes et les dommages possibles à l'autre équipement, ne pas installer pour contrôler une prise, un appareil moteur-fonctionné, ou un transformateur d'alimentation magnétique appareil fourni.

#### **Read Carefully Before Installing Dimmers:**

To avoid fire, personal injury, and/or damage to dimmer, turn power OFF at circuit breaker and test that power is OFF before wiring.

#### Notes:

- Fins must be mounted in vertical position and must not be recessed into the wall. When stacking dimmers or mounting one above the other, allow a minimum of three inches of clear wall space between the upper and lower finned plates.
- 2.) The aluminum chassis of this lighting control is designed as a heat sink to dissipate heat generated by the proper functioning of the circuit components. The fins may be very warm to the touch when the lighting control is operating at its maximum rated load. This is normal operation and does not indicate malfunction.
- 3.) Due to electro-magnetic radiation produced by all solid state lighting controls, the load, dimmer, and connecting wires should be located as far away as possible from radios, intercom units or public address systems. Six feet is the recommended minimum distance.
- 4.) Burn-in lamps at fullbright for a minimum 100 hours before attempting to dim and adjust trim.

5.) Dimmers may be ganged in any combination. See reverse for derating and wallbox size. **Wiring Diagrams:** See reverse side.


| Compatible Ballasts:          |  |  |  |
|-------------------------------|--|--|--|
| 277V                          |  |  |  |
| Universal 679-L-TC-P          |  |  |  |
| Universal 678-A-TC-P (2 lamp) |  |  |  |


Hunt Control Systems, Inc. 200 Rome Court Fort Collins, CO 80524 Ph: (970) 484-9048 www.huntdimming.com



# Wiring Diagrams and Ganging Information for HUNT Simplicity<sup>®</sup> Architecural Electromagnetic Fluorescent Controls Single Pole and Three Way 277V, 60Hz


# **Standard Installation** Single Pole Wiring Diagram





When ganging two dimmers, break off the inside fins; when ganging three or more, break off the inside fins of the outer units, and both sides of the inner unit(s). Break off as shown.

Derating of 10% per side is necessary when fins are removed.



#### Wallbox Requirements For Ganging

|   | NUIT | Number of double gang units |   |   |    |    |  |
|---|------|-----------------------------|---|---|----|----|--|
| Number<br>of<br>single<br>gang<br>units   |      | 0                           | 1 | 2 | 3  | 4  |  |
|   | 0    | _                           | 1 | 3 | 5  | 7  |  |
|   | 1    | 1                           | 3 | 5 | 7  | 9  |  |
|   | 2    | 2                           | 4 | 6 | 8  | 10 |  |
|   | 3    | 3                           | 5 | 7 | 9  | 11 |  |
|   | 4    | 4                           | 6 | 8 | 10 | 12 |  |
| Minimum size wall box required (in gangs) |      |                             |   |   |    |    |  |

#### Hunt Control Systems, Inc. 200 Rome Court Fort Collins, CO 80524 Ph: (970) 484-9048 www.huntdimming.com

#### LOW END BRIGHTNESS ADJUSTMENT THE LOW END BRIGHTNESS IS FACTORY

40 WATT LAMP

ADJUSTED. IF NOT SATISFACTORY, IT MAY BE TRIMMED AS FOLLOWS: Rotate dimmer control knob to full counterclockwise (with unit turned on). Adjust trim to desired brightness with a small screwdriver.

